



### ELEVATION

STANDARD ATTACHMENTS  
@ 12" O.C. MAX.

SHIM BY INSTALLER  
(AS REQUIRED)

SEALANT BY INSTALLER

OPTIONAL ATTACHMENT  
LOCATION @ 18" O.C. MAX.

BEB-16 BASE CHANNEL

HEAD BY OTHERS

ALUMINUM FLASHING  
EMBED IN BED OF  
SEALANT

SEALANT BY INSTALLER

BSSC-1 SNAP CAP

SCREW @ 12" O.C.

WPP-1 PRESSURE PLATE

GASKET (TYP.)

16mm PCSS

### SECTION 'A'

NOTE CORNER CONDITION:  
CAP(S) SQUARE CUT  
BASE CHANNEL SQUARE CUT

STANDARD  
ATTACHMENTS  
@ 12" O.C. MAX.

JAMB BY  
OTHERS

OPTIONAL ATTACHMENT  
LOCATION @ 18" O.C. MAX.

BMB-16 BASE CHANNEL

STANDARD ATTACHMENTS  
(2) @ 18" O.C. WHERE CONTINUOUS  
SUPPORT IS PROVIDED  
(OR)  
(4) @ PURLIN INTERSECTIONS

### SECTION 'B'

STANDARD ATTACHMENTS:

ALUMINUM:

#12 x 1" TEK SCREW W/ #3 TIP & NEOPRENE WASHER  
#12 x 2" TEK SCREW W/ #3 TIP & NEOPRENE WASHER

STEEL:

#12 x 2" TEK SCREW W/ #5 TIP & NEOPRENE WASHER

WOOD:

1/4" x 2" LAG SCREW W/ NEOPRENE WASHER

NOTE:

ATTACHMENT METHODS & SPACING BASED ON  
STANDARD 90 MPH WIND LOAD CONDITIONS.  
CONTACT DUO-GARD TO DISCUSS ALTERNATE  
LOAD CONDITIONS.

STRUCTURE BY OTHERS  
(ALUMINUM STRUCTURE  
CAN BE PROVIDED)

OPTIONAL ATTACHMENT  
LOCATION @ 18" O.C. MAX.

STANDARD ATTACHMENTS @  
12" O.C. MAX. INSTALLED  
THROUGH 1" x 1" x 1/2"  
NEOPRENE SPACER FULLY  
SET IN SEALANT

(2) 3/8" Ø WEEP HOLES  
@ 36" O.C. MAX.  
(ALONG SCREW LINE -  
MIN. 1" FROM SCREWS)

ALUMINUM FLASHING  
EMBED IN BED OF  
SEALANT

SILL BY OTHERS

### SECTION 'C' OPTIONAL ATTACHMENT



Duo-Gard Industries, Inc.  
Tel (734) 207-9700 Fax (734) 207-7995  
www.duo-gard.com

THIS DRAWING IS PROPRIETARY AND FOR THE SOLE USE OF OUR  
CUSTOMER AND MAY NOT BE COPIED OR REPRODUCED WITHOUT  
PRIOR WRITTEN CONSENT FROM DUO-GARD INDUSTRIES, INC.  
LEAD TIME BEGINS UPON RECEIPT OF SIGNED SHOP DRAWINGS

DESCRIPTION

SERIES 3000 BPC

SYSTEM 3016-3W

DWN BY	DRW'G DATE	SCALE	PAGE	OF	DRWNG #
JL	6/14/16	NTS	1	1	3016-3W G-16-3W FLUSH